



CITY OF FRISCO PURCHASING DIVISION

January 31, 2012

Addendum #1

Revised Specification for Option 2 8 Ton Liebert Unit

Bid # 1201-034

Liebert Unit for the City of Frisco Police Department Server Room

Option 2

One (1) 8 Ton Split Evaporator Liebert MiniMate2 Precision Cooling System, Model MMD96E7AHELD. The system will provide a total cooling capacity of 92,700 kBtuh and a sensible cooling capacity of 84,900 kBtuh at 75°F, 45% RH.

Split System Evaporator

- Includes evaporator coil, filter drier, thermal expansion valve, R-407C unit refrigerant charge, belt-driven blower, and microprocessor control with audible and visual alarms

One (1) Liebert Model PFH096A-AL7 Condensing Unit

- Includes condenser coil, hot gas bypass capacity control, R-407C unit refrigerant charge, scroll compressor and high head pressure switch.

Factory Installed Options:

- Electric Reheat
- Canister Humidifier
- Filter Clog Indicator
- Smoke Sensor
- Hot Gas Bypass Capacity Control
- Non-Locking Disconnect Switch

Ship-Loose Accessories

- 1 Sweat Adapters 3 Ton Circuit
- 1 Sweat Adapters 5 Ton Circuit
- 1 460 Volt Condensate Pump(s)
- 1 Condensate Pump Bracket(s)

- IS WEBADPT - SNMP Web Network Interface Card

Services Include:

- One year Parts only warranty
- 5 Year Compressor Only: Liebert 1st year standard parts only warranty + 2nd through 5th year compressor only extended warranty
- Warranty Inspection Start-Up

Vendors who may have already submitted a bid and feel this addendum may change their bid price, may pick up their bid, and return it by the closing date. If picking up the bid is not feasible, any new bid submitted by your firm will supersede one previously submitted.

Acknowledge receipt of this addendum by initialing in the appropriate space on the bid document.

Sincerely,

Jean Stelatella, CPIM, CPPB
Buyer
City of Frisco